

Electrical Contractor's Office 2016 Demo

Part 2: Importing data to certificates

Double click to import from:

"Dom EIC Form" "Dom EIC Pre 2011 Form"

"Dom EICR Form" "PIR Form"

ELECTRICAL INSTALLATION CONDITION REPORT

REPORT NUMBER

DETAILS OF CLIENT / PERSON ORDERING REPORT

Client

Address

EXTENT OF THE INSTALLATION AND LIMITATIONS

Extent of the
electrical installation
covered by this
report:
See notes below

DETAILS OF THE ELECTRICAL CONTRACTOR

Trading
Title: **P Jones Electrical Contractors Ltd**

Address: **12 Church Road
Hinckley
Leicestershire**

Postcode: **LE10 0EW**

Tel Number: **07003 332 122**

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations of the inspection and testing.

I/We further declare that in my/our judgement, the said installation was overall in condition at the time the inspection was carried out, and that it should be further inspected as recommended on page 6.

Inspected and tested by:

Name: **PETER JONES**

Signature: *Peter Jones*

Position: **Inspector**

Date:

Report authorised for issue by:

Name: **PETER JONES**

Signature: *Peter Jones*

Date:

SCHEDULES

Schedule(s) of inspection and schedule(s) of test results attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

Notes: This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671: 2015 (IET Wiring Regulations).

It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have not been visually inspected unless agreed between the client and inspector prior to the inspection.

Double click to import from:
 "Dom EIC Form"....."Dom EIC Pre 2011 Form".
 "Dom EICR Form"....."PIR Form".

ELECTRICAL INSTALLATION CONDITION REPORT

For premises up to 100A supply

REPORT NUMBER

Press Tab key after entering Report Number: EICR **1671**

DETAILS OF CLIENT / PERSON ORDERING REPORT		DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT	
Client	Manor House	Occupier	Manor House
Address	40 London Road Leicester LE1 3RR	Address	40 London Road Leicester LE1 3RR
		Estimated age of the wiring system	20 years
		Evidence of alterations or additions:	Yes If yes, estimated age: 3 years
		Date of previous inspection	Not Known installation records available: (Regulation 621.1) Yes

After a few seconds the data appears on the form.

EXTENT OF THE INSTALLATION AND LIMITATION	
Extent of the electrical installation covered by this report:	Full Installation
See notes below	

DETAILS OF THE ELECTRICAL CONTRACTOR	
Trading Title:	P Jones Electrical
Address	12 Church Road Hinckley Leicestershire
Postcode	LE10 0EW
Tel Number	07003 332122

Inspected and tested by:	Report authorised for issue by:
Name: PETER JONES	Name: PETER JONES
Signature: <i>Peter Jones</i>	Signature: <i>Peter Jones</i>
Position: Inspector	
Date: 05/04/16	Date: 05/04/16

SCHEDULES 2 Schedule(s) of inspection and 2 schedule(s) of test results attached. The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

Notes: This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671: 2015 (IET Wiring Regulations). It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have not been visually inspected unless agreed between the client and inspector prior to the inspection.

Double click to import from:
 "Dom EIC Form"....."Dom EIC Pre 2011 Form".
 "Dom EICR Form"....."PIR Form".

ELECTRICAL INSTALLATION CONDITION REPORT

For premises up to 100A supply

REPORT NUMBER

Press tab key after entering Report Number: EICR **1671**

DETAILS OF CLIENT / PERSON ORDERING REPORT		DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT	
Client	Manor House	Occupier	Manor House
Address	40 London Road Leicester LE1 3RR	Address	40 London Road Leicester LE1 3RR
		Estimated age of the wiring system	20 years
		Evidence of alterations or additions:	Yes If yes, estimated age: 3 years
		Date of previous inspection	Not Known installation records available: (Regulation 621.1) Yes

EXTENT OF THE INSTALLATION AND LIMITATIONS OF THE INSPECTION AND TESTING	REASON FOR PRODUCING THIS REPORT
Extent of the electrical installation covered by this report: Full Installation See notes below	

DETAILS OF THE ELECTRICAL CONTRACTOR	DETAILS OF THE INSPECTOR
Trading Title: P Jones Electrical	Inspector: PETER JONES
Address: 12 Church Road Hinckley Leicestershire	Signature: Peter Jones
Postcode: LE10 0EW	Position: Inspector
Tel Number: 07003 332122	Date: 05/04/16

Report authorised for issue by:
 Name: PETER JONES
 Signature: Peter Jones
 Date: 05/04/16

SCHEDULES 2 Schedule(s) of inspection and 2 schedule(s) of test results attached. The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

Notes: This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671: 2015 (IET Wiring Regulations). It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have not been visually inspected unless agreed between the client and inspector prior to the inspection.

SUMMARY OF THE INSPECTION

REPORT NUMBER

EICR

General condition of the installation

NEXT INSPECTION

Also refer to Observations and recommendations for actions to be taken on page 6.

Subject to the necessary remedial works being completed,

I/We recommend that this installation is further inspected and tested after an interval of not more than:

(Enter interval in terms of years or months, as appropriate)

Additional observation pages

Page no(s)

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements	Number and Type of Live Conductors	Nature of Supply Parameters	Supply Protective Device(s) Characteristics
TN-S <input type="checkbox"/>	1-phase, 2-wire <input type="checkbox"/> 2-phase, 3-wire <input type="checkbox"/>	Nominal voltages, U _i /U ₀ ⁽¹⁾ 230 V	B8 (EN) <input type="checkbox"/>
TN-C <input type="checkbox"/>	3 phase, 3-wire <input type="checkbox"/> 3-phase, 4-wire <input type="checkbox"/>	Nominal Frequency ⁽¹⁾ 50 Hz	Type <input type="checkbox"/>
TN-C-S <input type="checkbox"/>	(as detailed on attached inspection Schedule) Other <input type="checkbox"/>	Prospective fault current, I _{pf} ⁽²⁾ <input type="checkbox"/> kA	Rated current <input type="checkbox"/> A
TT <input type="checkbox"/>	Other (Details) <input type="checkbox"/>	External earth fault loop impedance, Z _e ⁽²⁾ <input type="checkbox"/> Ω	Short Circuit Capacity <input type="checkbox"/> kA
		Other sources of supply <input type="checkbox"/>	
(Note ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)			

PARTICULARS OF THE INSTALLATION REFERRED TO IN THIS REPORT

Mean of Earthing				Details of Installation Earth Electrode				Main Switch / Switch-Fuse / Circuit-breaker RCD			
Distributor's Facility <input type="checkbox"/>	Type <input type="checkbox"/>	Location <input type="checkbox"/>	Protective measures for fault protection <input type="checkbox"/>	Measured Z _e <input type="checkbox"/> Ω	Maximum demand (load) <input type="checkbox"/> kVA	Type B8(EN) <input type="checkbox"/>	Voltage rating 230 V				
Installation earth electrode <input type="checkbox"/>	Electrode resistance to earth R _a <input type="checkbox"/> Ω	Method of Measurement <input type="checkbox"/>	ADS <input type="checkbox"/>	Number of smoke alarms <input type="checkbox"/>	No of poles <input type="checkbox"/>	Current rating <input type="checkbox"/> A	Fuse/device rating or setting <input type="checkbox"/> A				
				Supply conductors material <input type="checkbox"/>				Supply conductors csa <input type="checkbox"/>			
				Location <input type="checkbox"/>				RCD operating current, I _{Δn} * <input type="checkbox"/> mA			
								RCD operating time, (at I _{Δn}) <input type="checkbox"/> ms			
Main protective conductors											
Earthing Conductor	Material Copper	csa <input type="checkbox"/> mm ²	Connection / continuity verified <input type="checkbox"/>	Water installation pipes <input type="checkbox"/>	Oil installation pipes <input type="checkbox"/>						
Main protective bonding conductors	Material Copper	csa <input type="checkbox"/> mm ²	Connection / continuity verified <input type="checkbox"/>	Gas installation pipes <input type="checkbox"/>	Structural steel <input type="checkbox"/>						
				Other incoming service(s) <input type="checkbox"/>	State Details <input type="checkbox"/>						

* applicable only where an RCD is used as a main circuit-breaker

SUMMARY OF THE INSPECTION

REPORT NUMBER
EICR 1671

General condition of the installation

The wiring in this installation is in good condition

The following have been visually inspected: Shower Isolation Switch, Shower, Hob Isolation Switch, Extractor Fan Relays, 8 Sockets, 3 Fused Spurs, 5 Outside Lights, 8 Internal Lights, Hall Track Spotlight, 5 Switches.

NEXT INSPECTION

Also refer to Observations and recommendations for actions to be taken on page 6.

Subject to the necessary remedial works being completed,

I/We recommend that this installation is further inspected and tested after an interval of not more than:

5 years

(Enter interval in terms of years or months, as appropriate)

Additional observation pages

Page no(s)

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements	Number and Type of Live Conductors	Nominal voltages
TN-S <input checked="" type="checkbox"/>	1-phase, 2-wire <input checked="" type="checkbox"/>	2-phase, 3-wire <input type="checkbox"/>
TN-C <input type="checkbox"/>	3 phase, 3-wire <input type="checkbox"/>	3-phase, 4-wire <input type="checkbox"/>
TN-C-S <input type="checkbox"/>	(as detailed on attached Inspection Schedule)	Other <input type="checkbox"/>
TT <input type="checkbox"/>	Other (Details)	

Data continues to import

Supply Protective Device(s) Characteristics

(EN) 1361

Type B

Rated current 100 A

Short Circuit Capacity 16 kA

(Note ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

PARTICULARS OF THE INSTALLATION REFERRED TO IN THIS REPORT

Mean of Earthing				Details of Installation Earth Electrode				Measured Z_e				Main Switch / Switch-Fuse / Circuit-breaker RCD			
Distributors Facility <input checked="" type="checkbox"/>	Type	Location	Protective measures for fault protection	Maximum demand (load)	Type BS(EN)	Voltage rating	Current rating	<td>0.13 Ω</td> <td>11 kVA</td> <td>80947-3</td> <td>230 V</td> <td>100 A</td>	0.13 Ω	11 kVA	80947-3	230 V	100 A		
Installation earth electrode <input type="checkbox"/>	Electrode resistance to earth R_A	Method of Measurement	ADS	Number of smoke alarms	No of poles	Fuse/device rating or setting									
					Supply conductors material	Supply conductors csa									
					Location	RCD operating current, $I_{\Delta n}$									
						RCD operating time, (at $I_{\Delta n}$)									
						* applicable only where an RCD is used as a main circuit-breaker									

Main protective conductors				Water Installation pipes				Oil Installation pipes			
Earthing Conductor	Material	csa	mm ²	Water Installation pipes	Gas Installation pipes	Structural steel					
	Copper	16		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>					
Main protective bonding conductors	Material	csa	mm ²	Other incoming service(s)	State Details						
	Copper	10		<input type="checkbox"/>							

REPORT NUMBER

EICR

Distribution Board (DB)

Reference No.

Location

Z, at DB

Ω

1-yr at DB

Details of circuits and/or installed equipment
vulnerable to damage when testing

Correct supply polarity confirmed

Phase sequence confirmed (where appropriate)

CIRCUIT DETAILS

TEST RESULTS

["Click here to delete test results"](#)

[illegible]

Click this box to create / update Distribution Board Chart

* /Record lowest value measured - Line/Line if applicable or Line(s)/Neutral/

⁴² (Record lowest value measured – Line(s)\Earth or Neutral\Earth)

"Create Continuation Form"

Codes for Type of Wiring

**A- Thermoplastic
insulated/sheath
cables**

B - Thermoplastic cables in metallic conduit

C - Thermoplastic cables in non-metallic conduit

D - Thermoplastic cables in metal trunking

E - Thermoplastic cables in no metallic trunk

F- Thermoplastic
BMA cable

tic/	G- Thermos
	cab

ding/BWA	H -
s	Insula

Mineral
d cables O - Ot
(ple

er Details
e state)

"Greets_Sub_Dist_Form"

TEST INSTRUMENTS

(Serial Numbers)

"Double click to enter the number of Continuation Forms you have created" ... If you are using Word 2003, double click this box and enter 0 to fix page numbering problems

Insulation resistance

Continuity

Earth fault loop Impedance

Multi-functional

Earth electrode resistance

RCD

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION

REPORT NUMBER

EICR

Distribution Board (DB)

Reference No

Location

Z_s at DB

Ω

I_{gr} at DB

kA

Details of circuits and/or installed equipment vulnerable to damage when testing

Correct supply polarity confirmed

Phase sequence confirmed (where appropriate)

CIRCUIT DETAILS

Circuit Ref	Circuit Description	Type of wiring (see code)	Reference method	Number of points served	Circuit conductors: csa		Max disconn time permitted by BS7671 (s)	Overcurrent protective devices				RCD Operating current, I _n (mA)	Maximum Z _s permitted by BS7671 (Ω)
					Live	cpc		BS (EN)	Type No	Rating (A)	Breaking Capacity (kA)		
					(mm ²)	(mm ²)							
						</							

TEST RESULTS

"Click here to delete test results."

Circuit Impedances (Ω)		Insulation resistance		Polarity	Measure earth fault loop impedance, Z _s	RCD / RCBO		Remarks
Continuity		L-L *	L-E **			Operating Times		
Ring final circuits only (measured end)	R _s = R ₂ or R ₁					at 30mA	at 50mA	
					</			

Data continues to import

Click this box to create / update Distribution Board Chart	* (Record lowest value measured - Line/Line if applicable or Line(s)/Neutral)				** (Record lowest value measured - Line(s)/Earth or Neutral/Earth)				Click here to delete test results	Click here to delete test results
Codes for Type of Wiring	A - Thermoplastic insulated/sheathed cables	B - Thermoplastic cables in metallic conduit	C - Thermoplastic cables in non-metallic conduit	D - Thermoplastic cables in metallic trunking	E - Thermoplastic cables in non-metallic trunking	F - Thermoplastic / SWA cables	G - Thermosetting / SWA cables	H - Mineral insulated cables	O - Other Details (please state)	Click here to delete test results

TEST INSTRUMENTS

(Serial Numbers)

"Double click to enter the number of Continuation Forms you have created".

Insulation resistance		Continuity		Earth fault loop Impedance	
Multi-functional		Earth electrode resistance		RCD	

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION DB1

REPORT NUMBER

EICR 1671

Distribution Board (DB)
Reference No

DB1

Location

Hall Cupboard

Details of circuits and/or installed equipment
vulnerable to damage when testing

Fire Alarm, Intruder Alarm, Emergency Lights

Z_s at DB

0.13

Ω

I_{pn} at DB

1.81

kA

Correct supply polarity confirmed

☒ Phase sequence confirmed (where appropriate)

CIRCUIT DETAILS

Circuit Ref	Circuit Description	Type of wiring (see code)	Reference method	Number of points served	Circuit conductors: csa			Max disconn time permitted by BS7671 (s)	Overcurrent protective devices				RCD	
					Live	cpc			BS (EN)	Type No	Rating (A)	Breaking Capacity (kA)	Operating current, In (mA)	Maximum Z _s permitted by BS7671
(mm ²)	(mm ²)													
1	Fire Alarm	A	C	1	1.5	1.5	0.4	61009-1	B	6	6	30	7.28	
2	Spare Blanked Off													
	RCD			5			0.4	61009-1	B	30	6	30	0.55	
	RCD			5			0.4	61009-1	B	30	6	30	0.55	
3	Kitchen Ring Left Hand Side & Combi Boiler	A	101	3	2.5	1.5	0.4	60898	B	20	6	30	2.19	
4	Shower	A	101	1	10.0	4.0	0.4	60898	B	40	6	30	1.09	
5	Ring Main Foyer & Store Room	A	101	4	2.5	1.5	0.4	60898	B	20	6	30	2.19	
6	Lighting	A	101	18	1.5	1.0	0.4	60898	B	10	6	30	4.37	
7	Lighting	A	101	14	1.5	1.0	0.4	60898	B	6	6	30	7.28	
8	Spare Blanked Off													
9	Spare Blanked Off													
	RCD			5			0.4	61009-1	B	30	6	30	0.55	
10	Ring Main Hall / Disco Room	A	101	13	2.5	1.5	0.4	60898	B	32	6	30	1.37	
11	Extractor Fans	A	101	2	2.5	1.5	0.4	60898	B	16	6	30	2.73	
12	Lighting	A	101	11	1.5	1.0	0.4	60898	B	6	6	30	7.28	
13	Lighting	A	101	1	1.5	1.0	0.4	60898	B	6	6	30	7.28	
14	Lighting	A	101	5	1.5	1.0	0.4	60898	B	6	6	30	7.28	

TEST RESULTS

"Click here to delete test results"

Circuit Impedances (Ω)					Insulation resistance		Polarity	Max measure earth fault loop impedance, Z _s	RCD / RCBO		functional Testing	Remarks
Continuity			R ₁ + R ₂ or R ₃	L-L *	L-E **	Operating Times						
Ring final circuits only (measured end to end)						at I _{Δn}			at 5I _{Δn}			
L-L	N-N	CPC-CPC				(ms)			(ms)			
R ₁ + R ₂	R ₃	(MΩ)	(MΩ)	(V)	(Ω)	(ms)	(ms)					
				0.37	>100	>100	✓	0.90	23.6	19.2	✓	
											✓	
							✓		46.6	30.4	✓	
							✓		46.6	30.4	✓	
0.65	0.64	>100		0.15	>100	>100	✓	0.56			✓	6.0mm T & E From CU
				0.14	>100	>100	✓	0.23			✓	
				0.36	>100	>100	✓	0.89			✓	Radial Circuit
				0.26	>100	>100	✓	0.77			✓	Measured Middle Room E Light
				0.45	>100	>100	✓	1.39			✓	Measured Outside Light Near Front Door
							✓		40.0	16.0	✓	
							✓		40.0	16.0	✓	
0.65	0.69	1.15		0.42			✓	0.56			✓	
				0.15	>100	>100	✓	0.48			✓	Relay Switches in Office
				0.63	>100	>100	✓	1.62			✓	
				0.07	>100	>100	✓	0.16			✓	
				0.61	>100	>100	✓	1.27			✓	

Click this box to create / update Distribution Board Chart

* (Record lowest value measured - Line/Line if applicable or Line(s)/Neutral)

** (Record lowest value measured - Line(s)/Earth or Neutral/Earth)

Click here to create Continuation Form

Codes for Type of Wiring

A - Thermoplastic insulated / sheathed cables

B - Thermoplastic cables in metallic conduit

C - Thermoplastic cables in non-metallic conduit

D - Thermoplastic cables in metallic trunking

E - Thermoplastic cables in non-metallic trunking

F - Thermoplastic / SWA cables

G - Thermosetting / SWA cables

H - Mineral insulated cables

O - Other Details (please state)

Click here to create Sub-Dist Form

TEST INSTRUMENTS (Serial Numbers)

"Double click to enter the number of Continuation Forms you have created" ... If you use Word 2003, double click this box and enter 0 in the main continuation spreadsheet

Insulation resistance	224693	Continuity	224693	Earth fault loop impedance	224693
Multi-functional	224693	Earth electrode resistance		RCD	224693

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION DB1

REPORT NUMBER

EICR 1671

Distribution Board (DB) DB1

Reference No

Location

Hall Cupboard

Details of circuits and/or installed equipment vulnerable to damage when testing

Fire Alarm, Intruder Alarm, Emergency Lights

Z_s at DB

0.13

Ω

I_{tr} at DB

1.81

kA

Correct supply polarity confirmed

Phase sequence confirmed (where appropriate)

CIRCUIT DETAILS

Circuit Ref	Circuit Description	Type of wiring (see code)	Reference method	Number of points served	Circuit conductors: csa			Overcurrent protective devices				RCD	
					Live	cpc	Max discon time permitted by BS7671	BS(EN)	Type No	Rating	Breaking Capacity	Operating current, I _n	Maximum Z _s permitted by BS7671
(mm ²)	(mm ²)	(s)			(A)	(kA)	(mA)						
1	Fire Alarm	A	D	1	1.5	1.5	0.4	61009-1	B	6	6	30	7.28
2	Spare Blanked Off												
	RCD			6			0.4	61009-1	B	80	6	30	0.55
	RCD			6			0.4	61009-1	B	80	6	30	0.55
3	Kitchen Ring Left Hand Side & Combi Boiler	A	101	3	2.5	1.5	0.4	60898	B	20	6	30	2.19
4	Shower	A	101	1	10.0	4.0	0.4	60898	B	40	6	30	1.09
5	Ring Main Foyer & Store Room	A	101	4	2.5	1.5	0.4	60898	B	20	6	30	2.19
6	Lighting	A	101	18	1.5	1.0	0.4	60898	B	10	6	30	4.37
7	Lighting	A	101	14	1.5	1.0	0.4	60898	B	6	6	30	7.28
8	Spare Blanked Off												
9	Spare Blanked Off												
	RCD			6			0.4	61009-1	B	80	6	30	0.55
10	Ring Main Hall / Disco Room	A	101	13	2.5	1.5	0.4	60898	B	32	6	30	1.37
11	Extractor Fans	A	101	2	2.5	1.5	0.4	60898	B	16	6	30	2.73
12	Lighting	A	101	11	1.5	1.0	0.4	60898	B	6	6	30	7.28
13	Lighting	A	101	1	1.5	1.0	0.4	60898	B	6	6	30	7.28
14	Lighting	A	101	5	1.5	1.0	0.4	60898	B	6	6	30	7.28

TEST RESULTS

"Click here to delete test results"

Circuit Impedances (Ω)				Insulation resistance				RCD / RCBO				Remarks
Continuity				L-L* L-E**		Polarity	Max measure earth fault loop Impedance, Zs	Operating Times		Functional Testing		
Ring final circuits only (measured end to end)		R1 + R2 or Rn						at IΔn	at 5IΔn			
L-L	N-N	CPC-CPC	R1 + R2	Rn	(MΩ)	(MΩ)	(V)	(Ω)	(ms)	(ms)		

Circuit details are imported.

If the software detects older Max Zs values, it will ask if you wish to update them to Amendment 3 values.

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

Circuit details are imported.

If the software detects older Max Z_s values, it will ask if you wish to update them to Amendment 3 values.

Click this box to create / update Distribution Board Chart

Codes for Type of Wiring: A - Thermoplastic insulated / sheathed cables, B - Thermoplastic cables in metallic conduit, C - Thermoplastic cables in non-metallic conduit, D - Thermoplastic cables in metallic trunking, E - Thermoplastic cables in non-metallic trunking, F - Thermoplastic / BWA cables, G - Thermosetting / BWA cables, H - Mineral insulated cables, O - Other Details (please state)

TEST INSTRUMENTS (Serial Numbers)

Insulation resistance 224693 Continuity 224693 Earth fault loop Impedance 224693

Multi-functional 224693 Earth electrode resistance RCD 224693

"Double click to enter the number of Continuation Forms you have created"

"Create Continuation Form"

"Create Sub. Dist. Form"

SCHEDULE OF CIRCUIT DETAILS FOR THE INSTALLATION DB1

REPORT NUMBER

EICR 1671

Distribution Board (DB)
Reference No
Location

DB1

Hall Cupboard

Details of circuits and/or installed equipment
vulnerable to damage when testing

Fire Alarm, Intruder Alarm, Emergency Lights

Z_s at DB

0.13

Ω

I_{tr} at DB

1.81

kA

Correct supply polarity confirmed

Phase sequence confirmed (where appropriate)

CIRCUIT DETAILS

Circuit Ref	Circuit Description	Type of wiring (see code)	Reference method	Number of points served	Circuit conductors: csa		Max disconn time permitted by BS7671	Overcurrent protective devices				RCD	Maximum Z _s permitted by BS7671
					Live	cpc		BD(EN)	Type No	Rating	Breaking Capacity	Operating current, I _n	
					(mm ²)	(mm ²)							

TEST RESULTS

"Click here to delete test results"

Circuit Impedances (Ω)					Insulation resistance		Polarity	Max measure earth fault loop Impedance Zs	RCD / RCBO		Functional Testing	Remarks
Continuity			R1 + R2 or R2	L-L *	L-E **	Operating Times						
Ring final circuits only (measured end to end)						at I _{Δn}			at 5I _{Δn}			
L-L	N-N	OPC-OPC	R1 + R2	R2	(MΩ)	(MΩ)	(V)	(Ω)	(ms)	(ms)		
				0.37	>100	>100	✓	0.90	23.6	19.2	✓	
							✓		46.6	30.4	✓	
							✓		46.6	30.4	✓	
0.65	0.64	>100		0.15	>100	>100	✓	0.56			✓	6.0mm T & E From CU
				0.14	>100	>100	✓	0.23			✓	
				0.36	>100	>100	✓	0.39			✓	Radial Circuit
				0.26	>100	>100	✓	0.77			✓	Measured Middle Room Light
				0.45	>100	>100	✓	1.39			✓	Measured Outside Light Near Front Door
							✓		40.0	16.0	✓	
							✓		40.0	16.0	✓	
0.65	0.69	1.15		0.42			✓	0.56			✓	
				0.15	>100	>100	✓	0.48			✓	Relay Switches in Office
				0.63	>100	>100	✓	1.62			✓	
				0.07	>100	>100	✓	0.16			✓	
				0.61	>100	>100	✓	1.27			✓	

It will also ask if you wish to import test result values.

Click this box to create/update Distribution Board Chart

Codes for Type of Wiring

A- Thermoplastic insulated/sheathed cables

B- Thermoplastic cables in metallic conduit

C- Thermoplastic cables in non-metallic conduit

D- Thermoplastic cables in metallic trunking

E- Thermoplastic cables in non-metallic trunking

F- Thermoplastic/BWA cables

G- Thermosetting/BWA cables

H- Mineral insulated cables

O- Other Details (please state)

TEST INSTRUMENTS (Serial Numbers)

Insulation resistance 224693

Continuity 224693

Earth fault loop Impedance 224693

Multi-functional 224693

Earth electrode resistance

RCD 224693

"Double click to enter the number of Continuation Forms you have created"

Create Continuation Form

Create Sub-Data Form

REPORT NUMBER

EICR 1671

Distribution Board (DB)	DB1
Reference No	

Location	Hall Cupboard
----------	---------------

Z_0 at DB	0.13	Ω	I_{cr} at DB	1.81
-------------	------	----------	----------------	------

Details of circuits and/or installed equipment
vulnerable to damage when testing

Fire Alarm, Intruder Alarm, Emergency Lights

Correct supply polarity confirmed

☒ Phase sequence confirmed (where appropriate)

CIRCUIT DETAILS

TEST RESULTS

["Click here to delete test results"](#)

Circuit Ref	Circuit Description	Type of wiring (see code)	Reference method	Number of points served	Circuit conductors: csa		Max discon time permitted by BS7671	Overcurrent protective devices				RCD	Maximum Z _s permitted by BS7671	Circuit Impedances (Ω)		Insulation resistance			RCD / RCBO		Functional Testing	Remarks			
					Live	cpc		BS(EN)	Type No	Rating	Breaking Capacity			Operating current I _n	Maximum Z _s permitted by BS7671	Continuity		L-L* (MΩ)	L-E** (MΩ)	Polarity (V)			Max measure earth fault loop impedance Z _s (Ω)	Operating Times	
																Ring final circuits only (measured end to end)	R ₁ + R ₂ or R _s							at I _{Δn} (ms)	at 5I _{Δn} (ms)
1	Fire Alarm	A												>100	>100	✓	0.90	28.6	19.2	✓					
2	Spare Blanked Off																								
	RCD															✓		46.6	30.4	✓					
	RCD															✓		46.6	30.4	✓					
3	Kitchen Ring Left Hand Side & Combi Boiler	A												>100	>100	✓	0.56			✓	6.0mm T & E From CU				
4	Shower	A												>100	>100	✓	0.23			✓					
5	Ring Main Foyer & Store Room	A												>100	>100	✓	0.89			✓	Radial Circuit				
6	Lighting	A												>100	>100	✓	0.77			✓	Measured Middle Room Light				
7	Lighting	A												>100	>100	✓	1.39			✓	Measured Outside Light Near Front Door				
8	Spare Blanked Off																								
9	Spare Blanked Off																								
	RCD															✓		40.0	16.0	✓					
																✓		40.0	16.0	✓					
10	Ring Main Hall / Disco Room	A														✓	0.56			✓					
11	Extractor Fans	A												>100	>100	✓	0.46			✓	Relay Switches in Office				
12	Lighting	A												>100	>100	✓	1.62			✓					
13	Lighting	A												>100	>100	✓	0.16			✓					
14	Lighting	A												>100	>100	✓	1.27			✓					

Note: It is important to check form after import process and amend as required.

Note: It is important to check form after import process and amend as required.

[Click this box](#) to create / update Distribution Board Chart

* (Record lowest value measured - Line/Line if applicable or Line/Line/Line)

** (Record lowest value measured = LinearEARTH or NeutralEARTH)

Create Composite Point

Codes for Type of Wiring

A- Thermoplastic
insulated/ sheathed
cables

B - Thermoplastic cables in metallic conduit	C - Thermoplastic cables in non-metallic conduit
--	--

D - Thermoplastic cables in metallic trunking

F- Thermoplastic
BVA cables

G- Thermosetting
cables

BWA, H - Mineral
insulated cable

es O - Other Details
(please state)

15

Create

Sub. Dist. Form

TEST INSTRUMENTS (Serial Numbers)

"Double click to enter the number of Continuation Forms you have created" ... If you are using Word 2003, double click this box and enter 0 to fix page numbering problems.

Insulation resistance	224693
-----------------------	--------

Continuity 224693

Earth fault loop Impedance	224693
----------------------------	--------

Multi-functional	224693
------------------	--------

Earth electrode resistance

RCD	224693
-----	--------