

Double click here to insert your company header

Maximum Image Dimensions - 5.45cm x 18.5 cm  
747 x 164 pixels



Click Toggle Logo button in the Add-ins ribbon to remove this header

## EMERGENCY LIGHTING PERIODIC INSPECTION AND TESTING CERTIFICATE

CERTIFICATE NUMBER

ELPI

### CLIENT DETAILS

Name and  
Address

Postcode

### PURPOSE OF CERTIFICATE

To certify continued compliance of an  
existing installation

### INSTALLATION DETAILS

Address

Postcode

Extent of system  
covered by this  
Certificate

### CERTIFICATION

Contractor responsible for carrying out the  
inspection and testing – (Trading title)

Address:

Telephone Number:

Postcode:

I/We hereby certify that the emergency lighting system installation at the above premises has been inspected and tested by me/us in accordance with the "Results Schedule of items inspected and tested" on page 2, and to the best of my/our knowledge and belief, the installation complies at the time of my/our inspection and testing with the recommendations given in BS 5266-1: 2016 Emergency lighting Part 1: Code of practice for the emergency lighting of premises, BS EN 50172: 2004 / BS 5266-8: 2004 Emergency escape lighting systems – , except as stated below.

#### For the inspection and testing of the installation:

Name  
(Capitals)

Signature

Inspector

Date

### DETAILS OF DEPARTURES FROM THE CURRENT STANDARDS

Requirement Number

Details of deviations (Additional space to continue list is provided on page 3)

### RELATED REFERENCE DOCUMENTS

Electrical Installation Condition Report No. and/or  
date \* (most recent- covering the existing emergency  
lighting installation – see Note 1)

Other documents (if any) please state

### NEXT INSPECTION

 Enter interval in accordance with Clause 7.2 of BS EN 50172: 2004 / BS 5266-8: 2004

I/We recommend that this installation is further inspected and tested after an interval of not more than:

Note: 1. The wiring system of an existing emergency lighting system should have been periodically inspected and tested in accordance with BS 7671:2018 and an Electrical Installation Condition Report issued. Where applicable and where available, the serial number and/or the date of the most recent report should be recorded in the related reference document section.

# SCHEDULE OF ITEMS INSPECTED AND TESTED

Certificate Reference:

**ELPI**

**PURPOSE OF INSTALLED EMERGENCY LIGHTING SYSTEM** Tick applicable box(es)

Emergency escape lighting	<input type="checkbox"/>	Standby lighting	<input type="checkbox"/>
Escape route lighting	<input type="checkbox"/>	Partial standby lighting	<input type="checkbox"/>
Open area lighting	<input type="checkbox"/>	High risk task area lighting	<input type="checkbox"/>

**EMERGENCY LIGHTING INSTALLATION DETAILS** Tick applicable box(es)

Self-contained emergency luminaire	<input type="checkbox"/>	Combined emergency luminaire	<input type="checkbox"/>
Central battery system	<input type="checkbox"/>	Standby generator system	<input type="checkbox"/>

**CATEGORIES OF OPERATION FOR EMERGENCY LIGHTING SYSTEM**

Type	Mode	Facilities	Duration

**RESULTS OF INSPECTION AND TESTING**

\* If 'No' record the deviation on page 1.

BS 5266-1:2016 clause reference	Requirements	System Conforms (indicate with ✓)		
		Yes	No *	N/A
4.2	P1- Plans are available and correct			
Clause 5	P2- Under test conditions, adequate illumination provided for safe movement on the escape route and open areas.			
6.6	P3- Luminaires correctly positioned and oriented as shown on the plans			
Clause 10	P4- Original design still valid			
5.4	P5- All escape route safety signs and fire fighting equipment location signs visible with the normal lighting extinguished			
6.6	P6- Correct application and siting of additional emergency lighting			
6.7	P7- Luminaires conform to BS EN 60598-2-22			
6.7	P8- Luminaires have an appropriate Ingress Protection rating for their location, as specified in the system design.			
Clause 8	P9- Wiring systems comply with the requirements of BS 7671:2018			
8.2	P10- Fire protection of central wiring systems satisfactory (including cable supports)			
8.2.6	P11- Emergency lighting circuits correctly segregated from other supplies			
8.2.12	P12- Wiring to emergency lighting power supply sources a fixed installation, where a specialist plug and socket arrangement is used, it is protected against unauthorised interference			
8.3.3	P13- System has a suitable test facility for the application			
8.3.5	P14- Central power system output voltage range is compatible with the supply voltage range of the luminaires, taking into account supply cable voltage drop			
12.3	P15- Luminaires tested and found to operate for their full rated duration			
10.6	P16- Instructions for operations and maintenance			
Clause 11	P17- Test results in the logbook complete and satisfactory			
10.6; 10.7 Clause 11	P18- Instructions together with a suitable logbook showing a satisfactory commissioning test available for use by the building occupier			
Clause 12	P19- Luminaires clean and undamaged with lamps in good condition			
10.7 Clause 12	P20- Building occupier and their staff trained on suitable maintenance, testing and operating procedures, or a current maintenance contract is in place.			
12.1	P21- Evidence of servicing of Central Battery System (in line with manufacturer's procedures); in-house or current maintenance contract is in place.			
12.2	P22- Evidence of servicing of Standby Generator System (in line with manufacturer's procedures); in-house or current maintenance contract is in place.			
12.3	P23- After test the charging indicators operate correctly.			

\*\* This can be checked by visual inspection and checking that the illumination from the luminaires is not obscured and that minimum design spacings have been met

**TEST INSTRUMENTS USED**

Where periodic requirement P2 is carried out by measurement, details of instruments MUST be recorded.

Instrument 1 (light meter) Model	Serial Number	Instrument 2 (if any) Model	Serial Number

Notes: Important: all tests should be undertaken at times of minimum risk. If necessary, temporary emergency lighting should be installed until the emergency lighting batteries have been recharged.

